



Dentist Office TEST RESULTS Western New York



Test Dates
Waiting Room

Fungal Spore
Concentrations

Sept.05

1,115,333

Oct.05

2,000

Nov.05

960

Dec. 05

120



Test Dates
Patient Area

Fungal Spore
Concentrations

Sept.05

13,400

Oct.05


2,613

Nov.05

693

Dec. 05

227



Air Handlers are set on continuous fan. There are two 5 ton furnaces each has A 9016 unit with three lamps and a 75% Viledon filter. As well as a 1000KCS unit.

